



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

April 24, 2026

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Floyds Fork WQTC, KPDES No: KY0102784
Discharge Monitoring Report for March 2026.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Floyds Fork WQTC, for the month of March 2026.

There were no overflows, bypasses, or exceedances.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6000.

Sincerely,

Curt Otto
Process Supervisor

CO/ Floyds Fork 1/26.

Cc: V. Graves
B. Tinnell

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the [NPDES eReporting Help Desk](#) for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit																							
Permit #:				KY0102784				Permittee:				Floyds Fork WQTC MSD				Facility:				FLOYDS FORK WQTC MSD			
Major:				Yes				Permittee Address:				700 W Liberty St Louisville, KY 40203				Facility Location:				1100 BLUE HERON RD LOUISVILLE, KY 40245			
Permitted Feature:				001 External Outfall				Discharge:				001-1 MUNICIPAL DISCHARGE											
Report Dates & Status																							
Monitoring Period:				From 03/01/26 to 03/31/26				DMR Due Date:				04/28/26				Status:				NetDMR Validated			
Considerations for Form Completion																							
Principal Executive Officer																							
First Name:				James				Title:				Executive Director				Telephone:				502-540-6000			
Last Name:				Parrott																			
No Data Indicator (NODI)																							
Form NODI:				--																			
Code	Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type					
	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	9.0										19 - mg/L	0	01/07 - Weekly	GR - Grab			
					Permit Req.	>=	7.0 INST MIN										19 - mg/L		01/07 - Weekly	GR - Grab			
					Value NODI																		
00400	pH	1 - Effluent Gross	0	--	Sample	=	7.8						=	8.2		12 - SU	0	01/07 - Weekly	GR - Grab				
					Permit Req.	>=	6.0 MINIMUM					<=	9.0 MAXIMUM		12 - SU	01/07 - Weekly		GR - Grab					
					Value NODI																		
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	137.0	=	174.0	26 - lb/d		=	3.0	=	3.0	19 - mg/L	0	01/07 - Weekly	CP - Composite				
					Permit Req.	<=	1626.0 MO AVG	<=	2439.0 MX WK AV	26 - lb/d		<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L		01/07 - Weekly	24 - 24 Hour Composite				
					Value NODI																		
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample							=	831.0	=	1110.0	19 - mg/L	0	01/07 - Weekly	CP - Composite				
					Permit Req.								Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L		01/07 - Weekly	24 - 24 Hour Composite				
					Value NODI																		
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample							=	7.0	=	9.0	19 - mg/L	0	01/07 - Weekly	CP - Composite				
					Permit Req.								Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L		01/07 - Weekly	24 - 24 Hour Composite				
					Value NODI																		
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample	=	12.4	=	14.5	26 - lb/d		=	0.3	=	0.4	19 - mg/L	0	01/07 - Weekly	CP - Composite				
					Permit Req.	<=	163.0 MO AVG	<=	244.0 MX WK AV	26 - lb/d		<=	3.0 MO AVG	<=	4.5 MX WK AV	19 - mg/L		01/07 - Weekly	24 - 24 Hour Composite				
					Value NODI																		
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample	=	19.0	=	32.4	26 - lb/d		=	0.4	=	0.6	19 - mg/L	0	01/07 - Weekly	CP - Composite				
					Permit Req.	<=	27.1 MO AVG	<=	40.7 MX WK AV	26 - lb/d		<=	0.5 MO AVG	<=	0.75 MX WK AV	19 - mg/L		01/07 - Weekly	24 - 24 Hour Composite				
					Value NODI																		
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	5.313	=	6.613	03 - MGD							0	99/99 - Continuous	CN - Continuous				
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	03 - MGD						99/99 - Continuous		RE - Record (manual)					
					Value NODI																		
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	4.756	=	6.044	03 - MGD							0	99/99 - Continuous	CN - Continuous				
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	03 - MGD						99/99 - Continuous		RE - Record (manual)					
					Value NODI																		
51040	E. coli	1 - Effluent Gross	0	--	Sample							=	1.0	=	4.0	13 - #/100mL	0	01/07 - Weekly	GR - Grab				
					Permit Req.							<=	130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL		01/07 - Weekly	GR - Grab				

					Value NODI													
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample = 129.0	=	174.0	26 - lb/d	=	3.0	=	3.0	19 - mg/L	0	01/07 - Weekly	CP - Composite		
					Permit Req. <= 325.0 MO AVG	<=	488.0 MX WK AV	26 - lb/d	<=	6.0 MO AVG	<=	9.0 MX WK AV	19 - mg/L	0	01/07 - Weekly	24 - 24 Hour Composite		
					Value NODI													
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample =				=	324.0	=	438.0	19 - mg/L	0	01/07 - Weekly	CP - Composite		
					Permit Req.					Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	0	01/07 - Weekly	24 - 24 Hour Composite		
					Value NODI													
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample =				=	99.0			23 - %	0	01/30 - Monthly	CA - Calculated		
					Permit Req. >=				>=	85.0 MO AV MN			23 - %	0	01/30 - Monthly	CA - Calculated		
					Value NODI													
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample =				=	100.0			23 - %	0	01/30 - Monthly	CA - Calculated		
					Permit Req. >=				>=	85.0 MO AV MN			23 - %	0	01/30 - Monthly	CA - Calculated		
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
FloydsForkCLMarch26.pdf	pdf	34573.0
FFMOR032026.pdf	pdf	75698.0

Report Last Saved By

Floyds Fork WQTC MSD

User: CURT.OTTO@LOUISVILLEMSD.ORG
 Name: Curt Otto
 E-Mail: curt.otto@louisvillemsd.org
 Date/Time: 2026-04-24 10:06 (Time Zone: -04:00)

Report Last Signed By

User: CURT.OTTO@LOUISVILLEMSD.ORG
 Name: Curt Otto
 E-Mail: curt.otto@louisvillemsd.org
 Date/Time: 2026-04-24 10:06 (Time Zone: -04:00)

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the [NPDES eReporting Help Desk](#) for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit																				
Permit #: KY0102784		Permittee: Floyds Fork WQTC MSD				Facility: FLOYDS FORK WQTC MSD														
Major: Yes		Permittee Address: 700 W Liberty St Louisville, KY 40203				Facility Location: 1100 BLUE HERON RD LOUISVILLE, KY 40245														
Permitted Feature: 001 External Outfall		Discharge: 001-2 TOXICITY																		
Report Dates & Status																				
Monitoring Period: From 01/01/26 to 03/31/26				DMR Due Date: 04/28/26				Status: NetDMR Validated												
Considerations for Form Completion																				
THREE 24-HOUR COMPOSITE SAMPLES ONE EACH COLLECTED EVERY OTHER DAY FOR A PERIOD OF 5 DAYS; IE - DAYS 1, 3 & 5																				
Principal Executive Officer																				
First Name: James				Title: Executive Director				Telephone: 502-540-6000												
Last Name: Parrott																				
No Data Indicator (NODI)																				
Form NODI: --																				
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
61406	Toxicity, final conc toxicity units	1 - Effluent Gross	0	--	Sample												0	01/90 - Quarterly	24 - 24 Hour Composite	
					Permit Req.											01/90 - Quarterly				24 - 24 Hour Composite
					Value NODI															
Submission Note																				
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																				
Edit Check Errors																				
No errors.																				
Comments																				
Attachments																				
No attachments.																				
Report Last Saved By																				
Floyds Fork WQTC MSD																				
User: CURT.OTTO@LOUISVILLEMSD.ORG																				
Name: Curt Otto																				
E-Mail: curt.otto@louisvillemsd.org																				
Date/Time: 2026-04-24 09:29 (Time Zone: -04:00)																				
Report Last Signed By																				
User: CURT.OTTO@LOUISVILLEMSD.ORG																				
Name: Curt Otto																				
E-Mail: curt.otto@louisvillemsd.org																				
Date/Time: 2026-04-24 10:06 (Time Zone: -04:00)																				

