



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.587.0603 | Fax: 502.540.6106 | louisvillemsd.org

February 18th, 2026

Ms. Crystal Dennis
300 Sower Blvd., 3rd Floor.
Frankfort, Kentucky 40601

**RE: Hite Creek WQTC, KPDES No: KY0022420
Discharge Monitoring Report for January 2026.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Hite Creek WQTC, for the month of January 2026.

There were no overflows, bypasses or exceedances.

If you have any questions concerning the attached DMR's, please contact me at (502) 540-6000.

Sincerely,

Curt Otto
Process Supervisor

CEO/Hite Creek 1/26.

cc: B. Tinnell
V. Graves
M. Saylor

					Value NODI														
51040	E. coli	1 - Effluent Gross	0	--	Sample	=	4.0	=	7.0	13 - #/100mL	03/07 - Three Per Week	GR - Grab							
					Permit Req.	<=	130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL	03/07 - Three Per Week	GR - Grab							
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	172.0	=	308.0	26 - lb/d	03/07 - Three Per Week	CP - Composite							
					Permit Req.	<=	751.0 MO AVG	<=	1127.0 MX WK AV	26 - lb/d	03/07 - Three Per Week	24 - 24 Hour Composite							
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample	=	165.0	=	225.0	19 - mg/L	03/07 - Three Per Week	CP - Composite							
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	03/07 - Three Per Week	24 - 24 Hour Composite							
					Value NODI														
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample	=	97.0			23 - %	03/07 - Three Per Week	CA - Calculated							
					Permit Req.	>=	85.0 MO AV MN			23 - %	01/30 - Monthly	CA - Calculated							
					Value NODI														
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	95.0			23 - %	03/07 - Three Per Week	CA - Calculated							
					Permit Req.	>=	85.0 MO AV MN			23 - %	01/30 - Monthly	CA - Calculated							
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
HCMOR012026.pdf	pdf	74111.0
HiteCreekCLJan26.pdf	pdf	35866.0

Report Last Saved By

Hite Creek WQTC MSD

User: CURT.OTTO@LOUISVILLEMSD.ORG
 Name: Curt Otto
 E-Mail: curt.otto@louisvillemsd.org
 Date/Time: 2026-02-20 13:19 (Time Zone: -05:00)

Report Last Signed By

User: CURT.OTTO@LOUISVILLEMSD.ORG
 Name: Curt Otto
 E-Mail: curt.otto@louisvillemsd.org
 Date/Time: 2026-02-20 13:19 (Time Zone: -05:00)

