



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

March 17th, 2026

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Country Village STP, KPDES No: KY0060577
Discharge Monitoring Report for February 2026**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Country Village STP, for the month of February 2026.

There were no overflows or bypasses. There were two exceedances. One for ammonia monthly average with a result of 16mg/L with a limit of 10mg/L. Second, for ammonia daily max with a result of 29.9mg/L with a permit limit of 15mg/L.

If you have any questions concerning the attached DMR's, please contact me at (502) 264-2804.

Sincerely,

Alex Smither
Process Supervisor

CAS/CV 2/26.

Cc: V. Teague, B. Tinnel

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

| Parameter | | Monitoring Location | Field | Type | Description | Acknowledge |
|-----------|--------------------------------|---------------------|---|------|--|-------------|
| Code | Name | | | | | |
| 00610 | Nitrogen, ammonia total [as N] | 1 - Effluent Gross | Quality or Concentration Sample Value 2 | Soft | The provided sample value is outside the permit limit. Please verify that the value you have provided is correct. | Yes |
| 00610 | Nitrogen, ammonia total [as N] | 1 - Effluent Gross | Quality or Concentration Sample Value 3 | Soft | The provided sample value is outside the permit limit. Please verify that the value you have provided is correct. | Yes |

Comments**Attachments**

| Name | Type | Size |
|--------------------------|------|---------|
| C_VILLAGE_COVER_2_26.pdf | pdf | 39648.0 |

Report Last Saved By**Louisville and Jefferson County MSD**

User: ALEX.SMITHER@LOUISVILLEMSD.ORG
 Name: Charles Smither
 E-Mail: alex.smither@louisvillemmsd.org
 Date/Time: 2026-03-17 12:38 (Time Zone: -04:00)

Report Last Signed By

User: ALEX.SMITHER@LOUISVILLEMSD.ORG
 Name: Charles Smither
 E-Mail: alex.smither@louisvillemmsd.org
 Date/Time: 2026-03-17 12:38 (Time Zone: -04:00)