



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

April 22<sup>th</sup>, 2026

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Country Village STP, KPDES No: KY0060577  
Discharge Monitoring Report for March 2026**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Country Village STP, for the month of March 2026.

There were no overflows or bypasses. There was one exceedance. It was for ammonia daily max with a result of 25.1 mg/L with a permit limit of 15mg/L. We pumped down and cleaned out the effluent lagoon. Our retest at the end of the month after cleaning resulted in a 1mg/l and a 0.61 mg/L which brought us into compliance for the monthly average.

If you have any questions concerning the attached DMR's, please contact me at (502) 264-2804.

Sincerely,

Alex Smither  
Process Supervisor

CAS/CV 3/26.

Cc: V. Teague, B. Tinnel



**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes

**Comments****Attachments**

Name	Type	Size
C_VILLAGE_COVER_3_26.pdf	pdf	40685.0

**Report Last Saved By****Louisville and Jefferson County MSD**

User: REED0325  
 Name: Scott Reed  
 E-Mail: reeds@louisvillemmsd.org  
 Date/Time: 2026-04-23 10:36 (Time Zone: -04:00)

**Report Last Signed By**

User: ALEX.SMITHER@LOUISVILLEMSD.ORG  
 Name: Charles Smither  
 E-Mail: alex.smither@louisvillemmsd.org  
 Date/Time: 2026-04-24 08:52 (Time Zone: -04:00)