



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

April 22<sup>nd</sup>, 2026

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Kentucky State Reformatory STP, KPDES No: KY00400126  
Discharge Monitoring Report for March 2026.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Kentucky State Reformatory STP, for the month of March 2026.

There were no exceedances, overflows or bypasses.

If you have any questions concerning the attached DMR's, please contact me at (502) 264-2804.

Sincerely,

Alex Smither  
Process Supervisor

CAS/KSR 3/26

Cc: V. Teague, B. Tinnel



					Value NODI															
01119	Copper, total recoverable	1 - Effluent Gross	0	--	Sample = 0.0145 = 0.021 19 - mg/L															01/07 - Weekly CP - Composite
					Permit Req. Req Mon MO AVG															01/07 - Weekly 24 - 24 Hour Composite
					Value NODI															
34306	Chlorodibromomethane	1 - Effluent Gross	0	--	Sample = 5.0 = 28 - ug/L															01/07 - Weekly CP - Composite
					Permit Req. <= 13.0 MO AVG															01/07 - Weekly 24 - 24 Hour Composite
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample = 0.772 = 0.872 03 - MGD															99/99 - Continuous RC - Recorder (auto)
					Permit Req. Req Mon MO AVG															99/99 - Continuous RC - Recorder (auto)
					Value NODI															
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample = 0.877 = 1.001 03 - MGD															01/07 - Weekly CA - Calculated
					Permit Req. Req Mon MO AVG															01/07 - Weekly CA - Calculated
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample = 0.01 = 0.01 19 - mg/L															01/07 - Weekly GR - Grab
					Permit Req. <= 0.011 MO AVG <= 0.019 DAILY MX															01/07 - Weekly GR - Grab
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample = 20.3 = 30.0 13 - #/100mL															01/07 - Weekly GR - Grab
					Permit Req. <= 130.0 30DA GEO <= 240.0 7 DA GEO															01/07 - Weekly GR - Grab
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample = 25.33 = 33.04 26 - lb/d															01/07 - Weekly CP - Composite
					Permit Req. <= 83.5 MO AVG <= 125.0 MX WK AV 26 - lb/d															01/07 - Weekly 24 - 24 Hour Composite
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample = 165.0 = 209.0 19 - mg/L															01/07 - Weekly CP - Composite
					Permit Req. Req Mon MO AVG															01/07 - Weekly 24 - 24 Hour Composite
					Value NODI															
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample = 97.4 = 23 - %															01/30 - Monthly CA - Calculated
					Permit Req. >= 85.0 MO AV MN															01/30 - Monthly CA - Calculated
					Value NODI															
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample = 97.7 = 23 - %															01/30 - Monthly CA - Calculated
					Permit Req. >= 85.0 MO AV MN															01/30 - Monthly CA - Calculated
					Value NODI															

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
KSR_COVER_3_26.pdf	pdf	36293.0

**Report Last Saved By**

**Louisville and Jefferson County MSD**

User: ALEX.SMITHER@LOUISVILLEMSD.ORG  
Name: Charles Smither  
E-Mail: alex.smither@louisvillemmsd.org  
Date/Time: 2026-04-24 08:33 (Time Zone: -04:00)

**Report Last Signed By**

User: ALEX.SMITHER@LOUISVILLEMSD.ORG  
Name: Charles Smither  
E-Mail: alex.smither@louisvillemmsd.org  
Date/Time: 2026-04-24 08:48 (Time Zone: -04:00)